

Appendix B

Certified Validation Report Template, Part A: Provided by Validator

Audit Information:

Water Supplier Name: PWS ID: 1010001
Bakman Water Company
System Type: Potable Audit Period: January 1 2017 through December 31, 2017

Utility Representation: Yes

Validation Date: Call Time: Sufficient Supporting Documents Provided: Yes
September 26, 2018 through 9/26/18 - 3:00 -3:30 PM
September 27, 2018 9/27/18 - 2:00 - 2:30 PM

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 69 Data Validity Band (Level): III

ILI: 5.13 Real Loss: 76.957 MG/Yr Apparent Loss: 4.810 MG/Yr

Non-revenue water as percent of cost of operating system: 4.6%

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

If not, rejected recommendations are included here.

Validator Information:

Water Audit Validator:  Qualifications: Water Audit Validator Certificate issued by the CA-NV Section of the AWWA

Nicholas J. Jackson

Validator Provided

Certified Validation Report Template, Part B: Provided by Utility

Water Supplier Name:
Bakman Water Company

Water Supplier ID Number: 1010001

Water Audit Period:
January 1 2017 through December 31, 2017

Water Audit & Water Loss Improvement Steps:

Utility to provide steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:

Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audit and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Executive Name (Print)

Richard Shaymus Bakman

Executive Position

Vice President

Signature



Date

10/1/2018

Utility Provided